
ADDENDUM

Project:	Garvin Park Activity Zone 45 Don Mattingly Way Evansville, Indiana	Addendum No.:	001
		Date:	May 23, 2025
Owner:	Evansville Parks and Recreation 100 East Walnut Street Evansville, Indiana 47713	Project Number:	2402-146
		Contract for:	General

The original specifications and drawings dated **Enter Month, Year** for the project noted above are amended as noted in this Addendum Number **Enter Addendum Number**. Receipt of this addendum and any subsequent addenda must be acknowledged on the final bid documents. This addendum consists of **item(s)** and attachment(s).

1. Invitation For Bids, Proposals Due, CHANGE TO:

Wednesday June 4 at 12:00 Noon CST
1 NW Martin Luther King Jr. Blvd.
Evansville, IN 47708
Room 301

2. Invitation For Bids, 12. Delivery of Bids, The submittals must be sealed and clearly labeled, CHANGE TO:

IFB-GARVIN PARK ACTIVITY ZONE
1 NW Martin Luther King Jr. Blvd.
Room 323 Evansville, Indiana 47708
Bid Open Date: **June 4, 2025**

3. Invitation For Bids, 12 Delivery of Bids, CHANGE TO:

Bids must be delivered by 11:45 am CDT on **June 4, 2025** to the following address:

Purchasing Department
1 NW Martin Luther King, Jr. Blvd. Room 323
Evansville, Indiana 47708

NOTE: Any bids submitted after 11:45 am on **June 4, 2025** but before the scheduled opening at 12:00 pm CDT shall be delivered to **Room 301** Civic Center, 1 NW Martin Luther King Jr. Blvd., Evansville, Indiana 47708.

4. Invitation For Bids, Project Schedule, CHANGE TO:

June 4, 2025 Sealed Bids Are Due

June 11, 2025 The Contract to be awarded to the Successful Bidder

5. Specification 012300 ALTERNATES, 3.1 Schedule of Alternates, ADD THE FOLLOWING:

C. Alternate No. 3: If Alternate No. 1 is accepted, indicate Add, Deduct, or No Change to the contract price to construct basketball courts of Portland Cement concrete pavement in lieu of asphalt pavement, conforming to Specification 321313 Concrete Paving. Concrete pavement at basketball courts shall be 5" thick over 4" minimum compacted stone subbase with #3 rebars at 1'-6" on center both ways. Provide continuous expansion joints between the basketball court pavement and perimeter walks, all around. Provide an expansion joint midway between the basketball courts from the perimeter walk north of the courts to the perimeter walk south of the courts, conforming to detail 2/L2.1. Surface finish of concrete shall conform to sports surface manufacturer's requirements.

6. Specification 087100 DOOR HARDWARE, Door Hardware Sets, Hardware Set #2, lockset function, CHANGE TO:

ND92 / ANSIF109.

7. Specification 321823 ATHLETIC SURFACING, PART 1, ADD THE FOLLOWING:

1.6 WARRANTY

- A. Minimum one year for full cost of repair or replacement by manufacturer and installer.**

8. Specification 321823 ATHLETIC SURFACING, article 3.3, ADD THE FOLLOWING:

E. Colors: A maximum of two colors will be required for field areas of the basketball courts, not including white line paint.

9. Specification 321823 ATHLETIC SURFACING, article 2.1, ADD THE FOLLOWING:

- B. Approved substitutes for Basis of Design product:**

- 1. 'Plexipave' by ICP Solutions Group**

10. Drawing A1.1, DOOR TYPES, F1, the note regarding door louvers, CHANGE TO:

18" x 12" VANDAL-RESISTANT METAL LOUVER WITH ALUMINUM INSECT SCREEN, TAMPER-PROOF TORX SECURITY SCREWS, POWDER-COATED COLOR AS APPROVED BY ARCHITECT – BASIS OF DESIGN PRODUCT: NGP L-VRSG-3 FOR 1 ¾" THICK DOORS.

11. Drawing EC1.1 DEMOLITION AND EROSION CONTROL PLAN, regarding Reference Note 11, CHANGE TO:

REMOVE AND DISPOSE OF EXISTING PLAYGROUND EQUIPMENT AND SITE FURNITURE IF NOT ALREADY SALVAGED BY OWNER

12. Drawing L1.1 HARDSCAPE PLAN, Reference Note 18 regarding asphalt paving, in the area on Herndon Drive where the water line connection occurs, ADD THE FOLLOWING:

18 – (PATCH STREET FOR WATER LINE CONNECTION)

13. Drawing L1.2 GRADING PLAN, General Grading Plan Notes, ADD THE FOLLOWING:

10. EXCESS SUITABLE SOIL, IF ANY, MAY BE DISPOSED OF ON GARVIN PARK PROPERTY, AS DIRECTED BY THE OWNER, IN LIEU OF REMOVAL FROM THE SITE. EXCESS SOIL SHALL BE FILLED, GRADED, AND COMPACTED CONFORMING TO SPECIFICATIONS 312000 AND 312001. SEED AND MULCH AREAS WHERE EXCESS SOIL IS PLACED IN ACCORDANCE WITH SPECIFICATION 329200.

Attachments: None

By: Daniel Engelbrecht

CC: