

DETAIL D-7

Concrete Drive Approach With No Sidewalk Detail No Scale (Rev. Date 10/31/97)

NOTES:

- $\widehat{\mbox{1}}$ All exposed edges shall be rounded with a 1/4" radius tool.
- ② Subgrade for Drive Approach shall be a minimum of 2" thick of either "B" Borrow of No. 53 Crushed Stone and mechanically compacted.
- 3 Additional contraction joints may be required depending on drive width.
- 4 Depressed Curb or Curb & Gutter through Drive to be paid as 6'' Curb or Curb & Gutter.
- (5) The cost of the Drive Approach shall include all of the above items, unless otherwise noted.