



NOTES:

- (1) Pipe Diameter $\leq 24"$, 6" width
Pipe Diameter $> 24"$, 12" width
- (2) Pipe Diameter $\leq 24"$, 4" width
Pipe Diameter $> 24"$, 6" width
- (3) Pavement Patch:
Asphalt Drive - 1" H.A.C. Surface, 9.5 mm; 2" H.A.C. Binder, 19mm; 4" #53 Crushed Stone
Asphalt Street - 1.5" H.A.C. Surface, 9.5mm; Tack Coat; 7" P.C.C. (3500psi)
or 1" H.A.C. Surface, 9.5mm; 9" H.A.C. Base, 25mm —See Plans
Note: If necessary increase street patch to match exist. pavement thickness.
Concrete Street & Drive - 6" P.C.C. (3500psi)
Rock Drive - 6" No. 53 Crushed Stone
Grass Drive - 6" Top Soil
- (4) Excavated material may be used for trench backfill on Grass Drive.
- (5) All backfill material shall be mechanically compacted in 6" lifts to 95% of standard density. (Except Flowable Fill)
- (6) All asphalt & concrete pavements shall be saw cut.
- (7) The cost of material shall be included in other items in the contract.
- (8) Material shall be paid for separately.

DETAIL E-1

Pipe Trench Backfill Details
No Scale (Rev. Date 09/03/03)