



#### NOTES:

- 1.) See Plans for casting size and type.
- 2.) Concrete for all connections shall be 3500 psi concrete. Precast concrete shall conform to ASTM C-478.
- 3.) Manhole shall be a precast "Tee" section for all new construction and shall be formed in place on existing pipe.
- 4.) The M.H. shall be backfilled per plans and specifications.
- 5.) The cost of the manhole shall include all of the above items.

## DETAIL A-4

24" R.C.P. M.H. for 18" Diameter Pipe and Greater  
Scale 3/4"=1' (Rev. Date 09/01/04)