



NOTES:

- 1.) See Plans for casting size and type.
- 2.) Concrete for poured base and concrete collars shall be 3500 psi concrete. Precast concrete shall conform to ASTM C-478.
- 3.) Base may be precast or poured in place concrete. When precast base is used, a 6" base of #53 crushed stone will be required. All connecting pipes shall be grouted with a 6" concrete collar.
- 4.) The M.H./Inlet shall be backfilled per plans and specifications.
- 5.) The cost of the manhole/inlet shall include all of the above items.

Precast Bottom (9"x39")  
Use No. 4Bars 6"  
Centers Bothways.  
Poured Bottom (12"x45")

# DETAIL C-3

M.H./Inlet 30" R.C.P. for 12" to 18" Diameter Pipe  
No Scale (Rev. Date 09/01/04)