

ADDENDUM ACKNOWLEDGEMENT FORM

---

SOLICITATION NO: IFB-508-01-23

SOLICITATION TITLE: HARTKE POOL STORM DAMAGE REPAIRS TO BATHHOUSE

OPENING DATE MARCH 15, 2023

ADDENDUM NUMBER: 2

DATE: March 8, 2023

PLEASE BE ADVISED THAT THE FOLLOWING QUESTIONS WERE RECEIVED CONCERNING THIS BID.

- 1) Please clarify that base bid is white EPDM, standard is black.  
Strike "Sure-White". Black EPDM should be the base bid.
- 2) Sure-white EPDM minimum thickness is 60 MIL, 45 MIL is listed on the roof plan  
45 mil is base bid for insurance purposes.
- 3) Maximum warranty for 45 MIL is 15 years. 25 year warranty requires a 60 MIL EPDM membrane or 80 MIL TPO membrane. 20 year warranty is 60 MIL membrane for both EPDM and TPO  
Make 45 mil, 15 year the base bid for insurance purposes. Provide alternate prices for 20 year and 25 year options at the owner's discretion.
- 4) Please clarify if a vapor barrier is required. If a vapor barrier is required, it will need to be from the roofing manufacturer. Carlisle 725 TR would be used for this application.  
After careful consideration, the vapor barrier may be omitted.

THIS ADDENDUM NOW BCOMES A PART OF THE ORIGINAL BID PACKET.

THE ADDENDUM ACKNOWLEDGEMENT FORM SHALL BE SIGNED BY AN AUTHROIZED COMPANY REPRESENTAVIE, DATED AND RETURNED WITH THE RESPONSE.

COMPANY: \_\_\_\_\_

BY: \_\_\_\_\_

TITLE: \_\_\_\_\_

DATE: \_\_\_\_\_

PHONE NUMBER : \_\_\_\_\_

SIGNATURE: \_\_\_\_\_